TRANSLATION FROM POLISH

GDAŃSK MEDICAL UNIVERSITY
Website : www.gumed.edu.pl
Tel. 58 349 11 11
Email info@gumed.edu.pl
Address ul. M. Skłodowskie-Curie 3a
80-210 Gdańsk

322/1245/384/2019 Gdańsk, 12-11-2019

HYGIENIC CERTIFICATE No 379/322/384/2019

1. **Product (material)** **MDF/HDF FIBREBOARD**
   thickness: 2,0 +60,0 mm

2. **Application** furniture and interior finishing

3. **Application institution** Kronospan Polska Sp. z o.o.
   ul. Waryńskiego 1
   78-400 Szczecinek

4. **Manufacturer** Kronospan Polska Sp. z o.o.
   ul. Waryńskiego 1
   78-400 Szczecinek

5. The product was evaluated positively as regards hygienic requirements on the following conditions:
   - loading ratio 0,6 m^2/m^3 capacity of living quarters, places destined for permanent stay of the sick in health services buildings and places destined for permanent stay of children and teenagers in education buildings, and places destined for food storage, i.e. A category places.
   - loading ratio 1,2 m^2/m^3 capacity of places destined for stay of people other than classified as A category places and in auxiliary quarters of apartments, i.e. B category places according to the Act of the Minister of Health and Social Care of 12 March 1996 – M.P. 1996 No 19 item 231.

   The certificate does not concern working conditions and industrial safety during the assembly of the product.
   Places where the above mentioned product was applied should be ventilated.
6. Basis of the certificate: application of Kronospan Polska Sp. z o.o. of 22-10-2019, Test report No 8105/247/2019 of 07-02-2019 issued by Ośrodek Badawczo-Rozwojowy Przemysłu Płyt Drewnopochodnych Sp. z o.o. [Research and Development Centre for Wood Based Panels] in Czarna Woda.
   Hygienic class E-1.
7. The certificate may be changed or made void if either party presents sufficient evidence. The document becomes invalid after 5 years from the date of its issue or if any changes either in composition or manufacturing technology have been introduced.

[a seal affixed:
MANAGER
Environmental Toxicology Laboratory
/illegible signature/
Lidia Wolska, Ph.D]

I, Halina Kaniewska, a sworn translator of English, No TP/2705/05, hereby certify that this is a true translation of the document presented to me.

Toruń, 18.11.2019 No 1499/2019