



CERTIFICATE

NR 25/205/2020

1. **Name of product :** **Boards Type OSB/3**
2. **Customer :** **Kronospan UA LLC**
20 Lutska Str.
Novovolynsk, Volyn Region
Ukraine, 45400
3. **Producer:** **Kronospan UA LLC**
20 Lutska Str.
Novovolynsk, Volyn Region
Ukraine, 45400
4. **Particulars on the product:**
 - date of production: 01.11.2020
 - date of delivery research in OB-RPPD: 10.11.2020.
 - thickness: 9 mm
 - **acc. to the same technology are produced Kronospan UA LLC boards Type OSB/3 from 9 to 25 mm thickness**
5. **Specification of the determined substances: formaldehyde**
6. **Method and conditions of the tests:**
PN-EN 717-1:2006
 - method of the determination: chamber method (chamber capacity 0,225 m³)
 - tests conditions
 - temperature (23 ± 0,5)°C
 - relative humidity of the air (45 ± 3) %
 - number of exchanges the air per hour 1
 - loading of chamber with the test material 1 m²/1 m³,
 - determination of the formaldehyde - spectrophotometric method,
application of the acetylacetone
 - Results of the test includes: Test Report No 10161/205/2020.
7. **Date of the measurement:** 26.11 ÷ 04.12.2020.
8. **Quantity of emission formaldehyde:**

Thickness (mm)	Date of the measurement	equivalent concentration of formaldehyde in the air of chamber	
		(mg/m ³)	(ppm)
9	26.11. ÷ 04.12.2020	0,079	0,064

9. **Statement:**
The test results confirm the classification in emission formaldehyde class E1 of the EN 300:2006.

Czarna Woda, 04.12.2020

OB - RPPD spółka z o.o.
Kierownik
Laboratorium Badawczego

mgr inż. Mirosław Mrozek