Kronospan Trading Ltd

Holyhead Road Chirk Wrexham Clwyd LL14 5NT

Tel: 01691 773361 Fax: 01691 773292

e-mail: sales@kronospan.co.uk

website: www.kronospan-express.com



Agrément Certificate 13/4998

Product Sheet 3

KRONOSPAN WOOD-BASED PANEL

KRONOSPAN OSB/3 FOR SHEATHING

This Agrément Certificate Product Sheet⁽¹⁾ relates to Kronospan OSB/3 for Sheathing, a loadbearing oriented strand panel suitable for use as sheathing in timber-frame domestic buildings.

(1) Hereinafter referred to as 'Certificate'.

CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- · design considerations
- installation guidance
- · regular surveillance of production
- formal three-yearly review.

KEY FACTORS ASSESSED

Structural performance — the product, when incorporated into a structure, can contribute to structural strength and stiffness by distributing the dead and imposed loads to the supporting structure (see section 6).

Behaviour in relation to fire — the product does not achieve a reaction to fire classification of C-s2, d3 or better, and is restricted in some cases (see section 7).

Resistance to moisture — the product will have adequate moisture resistance (see section 8).

Durability — the product will have a service life equal to that of the structure in which it is incorporated (see section 11).

The BBA has awarded this Certificate to the company named above for the product described herein. This product has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Product of Agrément

Date of Third issue: 6 May 2022

Originally certificated on 12 June 2013

Hardy Giesler Chief Executive Officer

The BBA is a UKAS accredited certification body – Number 113.

The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers MUST check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA directly.

Any photographs are for illustrative purposes only, do not constitute advice and should not be relied upon.

British Product of Agrément

Bucknalls Lane

Watford

Herts WD25 9BA

tel: 01923 665300 clientservices@bbacerts.co.uk www.bbacerts.co.uk

©2022

Regulations

In the opinion of the BBA, Kronospan OSB/3 for Sheathing, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations (the presence of a UK map indicates that the subject is related to the Building Regulations in the region or regions of the UK depicted):



The Building Regulations 2010 (England and Wales) (as amended)

Requirement: A1 Loading

Comment: The product has sufficient strength and stiffness to sustain and transmit design

loads to the primary structure without excessive deflection. See section 6 of this

Certificate.

Requirement: B3(1)(3) Internal fire spread (structure)

Comment: The product can contribute to satisfying this Requirement. See section 7.2 of this

Certificate.

Requirement: B3(4) Internal fire spread (structure)

Comment: The product may be restricted by this Requirement. See section 7.1 of this

Certificate.

Regulation: 7(1) Materials and workmanship

Comment: The product is acceptable. See sections 11.1 and 11.2 and the *Installation* part of

this Certificate.

Regulation: 7(2) Materials and workmanship

Comment: The product is restricted by this Regulation. See sections 7.1 to 7.3 of this

Certificate.

The Building (Scotland) Regulations 2004 (as amended)

Regulation: 8(1) Durability, workmanship and fitness of materials

Comment: The use of the product satisfies the requirements of this Regulation. See sections

11.1 and 11.2 and the *Installation* part of this Certificate.

Regulation: 9 Building standards applicable to construction

Standard: 1.1(a)(b) Structure

Comment: The product has sufficient strength and stiffness to sustain and transmit design

loads to the primary structure without excessive deflection, in accordance with clauses $1.1.1^{(1)}$, $1.1.2^{(1)}$ and $1.1.3^{(1)}$ of this Standard. See section 6 of this Certificate.

Standard: 2.2 Separation

Standard: 2.3 Structural protection

Comment: The product can contribute to satisfying regulatory requirements in accordance

with clauses $2.2.1^{(1)}$, $2.2.6^{(1)}$, $2.2.7^{(1)}$, $2.2.8^{(1)}$, and $2.3.2^{(1)}$ of these Standards. See

sections 7.1 and 7.2 of this Certificate.

Standard: 2.4 Cavities

Comment: The product is restricted by this Standard with reference to clause 2.4.2⁽¹⁾. See

section 7.1 of this Certificate.

Standard: 2.6 Spread to neighbouring buildings

Comment: The product is restricted by this Standard with reference to clause 2.6.5⁽¹⁾. See

sections 7.1 and 7.4 of this Certificate.

Standard: 7.1(a) Statement of sustainability

Comment: The product can contribute to satisfying the relevant Requirements of Regulation 9,

Standards 1 to 6, and therefore will contribute to a construction meeting a bronze

level of sustainability as defined in this Standard.

Regulation: 12 Building standards applicable to conversions

Comment: All comments given for the product under Regulation 9, Standards 1 to 6, also apply

to this Regulation, with reference to clause $0.12.1^{(1)}$ and Schedule $6^{(1)}$.

(1) Technical Handbook (Domestic).

The Building Regulations (Northern Ireland) 2012 (as amended)

Regulation: 23(a)(i)(iii)(iv) Fitness of materials and workmanship

Comment: The product is acceptable. See sections 11.1 and 11.2 and the *Installation* part of

this Certificate.

Regulation: 30 Stability

Comment: The product can contribute to satisfying this Regulation. See section 6 of this

Certificate.

Regulation: 35 (1)(3) Internal fire spread — Structure

Comment: The product can contribute to satisfying this Regulation. See section 7.2 of this

Certificate.

Regulation: 35(4) Internal fire spread — Structure

Comment: The product may be restricted by this Regulation. See section 7.1 of this Certificate.

Construction (Design and Management) Regulations 2015 Construction (Design and Management) Regulations (Northern Ireland) 2016

Information in this Certificate may assist the client, designer (including Principal Designer) and contractor (including Principal Contractor) to address their obligations under these Regulations.

See sections: 1 Description (1.1), 3 Delivery and site handling (3.5) and 13 General of this Certificate.

Additional Information

NHBC Standards 2022

In the opinion of the BBA, Kronospan OSB/3 For Sheathing, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation to *NHBC Standards*, Chapters 6.2 *External timber-framed walls* and Chapter 6.3 *Internal walls*.

CE marking

The Certificate holder has taken the responsibility of CE marking the product in accordance with harmonised European Standard BS EN 13986 : 2004.

Technical Specification

1 Description

1.1 Kronospan OSB/3 for Sheathing is a loadbearing oriented strand panel comprising softwood flakes/strands bonded together with MDI (methylene diphenyl diisocyanate) resin and wax. The product is manufactured in 13 standard thicknesses with the dimensions given in Table 1.

Thickness (mm) (kg·m ⁻³) Panel size (mm) 6 8 9 10 11 12 14 15 580 16	Table 1 Product dimensions		
6 8 9 10 11 12 14 15 15 16			
9 610 11 12 2440 x 1220 15 580		(1.8)	()
10 11 12 14 15 15 16	_		
11 12 14 2440 x 1220 15 580 16	_	610	
14 2440 x 1220 15 580 16	-		
15 580 16	12		
16	14		2440 x 1220
 	15	580	
10	16		
10	18		
22 570	22	570	
_25	25		
32 550	32	550	

1.2 The product is available with square or tongue-and-groove edges.

2 Manufacture

- 2.1 The product is manufactured to the specification detailed in BS EN 300: 2006 for OSB/3 loadbearing oriented strand products. Timber logs, to the Certificate holder's specification, are debarked and cut to length before passing through a flaking machine. After drying and screening to remove fines, the strands/flakes are blended with MDI resin and wax and formed into a three-ply mat, which is pressed and cured under pressure and temperature, and cut to size.
- 2.2 As part of the assessment and ongoing surveillance of product quality, the BBA has:
- · agreed with the manufacturer the quality control procedures and product testing to be undertaken
- assessed and agreed the quality control operated over batches of incoming materials
- monitored the production process and verified that it is in accordance with the documented process
- evaluated the process for management of nonconformities
- checked that equipment has been properly tested and calibrated
- undertaken to carry out the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.
- 2.3 The management system of the manufacturer has been assessed and registered as meeting the requirements of BS EN ISO 9001: 2015 by BM TRADA (Certificate 2238, Issue number: 2022-01).

3 Delivery and site handling

- 3.1 Handling, storage and delivery of the product should be carried out in accordance with the requirements of PD CEN/ TR 12872 : 2014 and BS 8103-3 : 2009, and *NHBC Standards* 2022 where required.
- 3.2 To prevent distortion, panels should be stacked flat with all four edges flush or clear of the floor on level bearers at centres not exceeding 600 mm. The stack of panels must be kept in an enclosed dry area or under a waterproof cover, with the edges protected to prevent warping.
- 3.3 The product should be stored in a dry environment.
- 3.4 Each panel is marked in accordance with the requirements of BS EN 13986 : 2004 and with the BBA logo incorporating the number of this Certificate.
- 3.5 For delivery, panels are banded together in bundles up to 1.7 tonnes in weight and 900 mm in height. The panels are covered in transit to minimise changes in moisture content. Particular care should be taken to protect the edges and corners. Banding should be cut on arrival at site but protective covering should not be removed until the panels are ready for conditioning (see section 8.4).

Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on Kronospan OSB/3 for Sheathing.

Design Considerations

4 General

- 4.1 Kronospan OSB/3 for sheathing is satisfactory for use as structural sheathing in timber-frame walls of domestic buildings.
- 4.2 Fabrication and installation of sheathing products, including the provision of moisture expansion gaps, must be in accordance with PD CEN/TR 12872 : 2014 and BS EN 1995-1-1 : 2004. Exposure to the elements should be minimised during installation.
- 4.3 The timber structures in which the product is incorporated must be designed and constructed to comply with BS EN 1995-1-1: 2004.
- 4.4 In accordance with BS EN 300: 2006, the product is satisfactory for use in environmental conditions covered by Biological Hazard Classes 1 and 2 for wood and wood-based products, as defined in BS EN 335: 2013. In such environments, the product is covered and fully protected from the elements. As a general rule, it is recommended that the moisture content of the product should not exceed 12% in accordance with BS 8103-3: 2009. Prolonged exposure to an air temperature of 20°C and a relative humidity of 90% may result in the recommended moisture content being exceeded.
- 4.5 The design thermal conductivity (λ value) of OSB, given in BS EN 12524 : 2000, is 0.13 W·m⁻¹·K⁻¹ and as such will not have a significant effect on the thermal transmittance (U value) of the wall construction.

5 Practicability of installation

The product is designed to be installed by a competent general builder, or a contractor, experienced with this type of product.

6 Structural performance



- 6.1 The safe racking resistance of a timber-frame wall incorporating OSB sheathing nailed to studding should be determined by test according to BS EN 594: 2011 in accordance with the guidance given in BS EN 1995-1-1: 2004, by a suitably experienced and qualified individual, based upon the vertical design load on the wall and the nail spacing and nail characteristics used to attach the sheathing.
- 6.2 As a guide, when calculated in accordance with BS EN 1995-1-1: 2004, Method B, the basic racking resistance of a timber-frame wall⁽¹⁾ without vertical loading and with 9 mm thick sheathing fixed with nails⁽²⁾ at 100 mm spacing is $3.62 \text{ kN} \cdot \text{m}^{-1}$, and at 150 mm spacing $2.77 \text{ kN} \cdot \text{m}^{-1}$.
- (1) Studs: timber grade C16, minimum size 38 mm by 75 mm and spaced at a maximum of 600 mm.
- (2) Nails: minimum diameter 3.1 mm, minimum length 50 mm and ultimate tensile strength 700 $N\cdot mm^{-2}.$

7 Behaviour in relation to fire



- 7.1 The product does not achieve a reaction to fire classification of C-s2, d3 or better.
- 7.2 The fire resistance of wall constructions incorporating the product may be calculated with reference with reference to BS EN 1995-1-2: 2004 and its UK National Annex or, where necessary, the fire resistance should be confirmed by an appropriate tests or assessments by a suitably accredited laboratory.



7.3 In England and Wales, the product should not be used on external walls of buildings that have a storey at least 18 m above ground level.



- 7.4 In Scotland, the product may be used more than 1 m from a boundary. The product should not be used on external walls of domestic buildings with a floor more than 18 m above the ground. Additional restrictions apply for separating elements.
- 7.5 Designers should refer to the relevant national Building Regulations and guidance for detailed conditions of use, particularly in respect of requirements for fire resistance, cavity barriers, service penetrations and combustibility limitations for other materials and combustibility limitations for other materials and components used in the overall wall construction (for example, thermal insulation and cladding).
- 7.6 Where the product is incorporated in a wall construction where fire resistance is required by the documents supporting the national Building Regulations, the fire resistance should be confirmed by tests or assessments by a suitably accredited laboratory.

8 Resistance to moisture

- $8.1\,$ In common with all timber products OSB is subject to moisture movement. As a guide, it may be assumed that a 1% change in product moisture content will cause a dimensional change in product length $0.2\,$ mm per meter run, panel width by $0.3\,$ mm per meter run and product thickness by 0.5%.
- 8.2 Under similar environmental conditions, OSB will take longer to equilibrate and will attain an equilibrium moisture content approximately 2% to 3% lower than solid timber.
- 8.3 To avoid distortion and damage to finishes, expansion gaps, in accordance with the recommendations of PD CEN/TR 12872 : 2014, or BS 8103-3 : 2009, and with *NHBC Standards* 2022 where required, should be provided when installing the product.
- 8.4 To minimise subsequent movement, before installation all wet site operations should be completed and the products conditioned as close as is practicable to the environmental conditions likely to occur in service. To achieve this, the maximum moisture content of the product at the time of installation or fixing, as determined using a properly calibrated moisture meter, should be close to the service class equilibrium moisture content (emc) values given in PD CEN/TR 12872 : 2014, Table 1, an extract of which is reproduced in Table 2 of this Certificate.

Table 2 Equilibrium moisture content and conditions of use			
Service	Approximate equilibrium	Conditions of use	
class	moisture content (emc)		
1	4% ≤ emc ≤ 11%	dry installations, no risk of wetting in service	
2	11% ≤ emc ≤ 17%	risk of wetting during installation and risk of occasional	
		wetting in service	
3	emc > 17%	risk of regular wetting in service	

- 8.5 Damp-proof membranes, breather membranes and vapour control layers should be incorporated as necessary in accordance with the requirements of BS 8103-3: 2009 and BS 5250: 2022.
- 8.6 In a wall construction, in calculations for interstitial condensation risk according to BS 5250 : 2022, the water vapour resistance factor (μ) of OSB can be taken as 50 (dry cup) from BS EN ISO 10456 : 2007, Table 3, depending on the construction, or as determined by testing in accordance with BS EN ISO 12572 : 2016.
- 8.7 In accordance with normal good practice for wood-based sheathing materials used in cold frame construction, external walls in which the product is incorporated must include an effective vapour control layer on the room side, suitable weather protection on the outside surface, a ventilated cavity and damp-proof courses. The product should be treated as conventional plywood sheathing with regard to detailing at openings, eaves and sole plate, the fixing of wall ties and breather membranes, and the effect of openings on racking strength.

- 8.8 The moisture content of sheathing material is affected by the humidity conditions existing in the cavity of which it forms one face. The cavity should be of conventional construction for timber framed buildings, freely drained and ventilated. The outer masonry leaf should have adequate resistance to wind-driven rain, particularly in regions classified as severe exposure. Raked mortar joints or high-porosity masonry should be avoided, particularly in these latter areas.
- 8.9 The outer weatherproofing should have adequate resistance to wind-driven rain, particularly in regions classified as severe exposure.

9 Formaldehyde content

In common with other wood-based products, which include formaldehyde as a component of the resin, the product may emit small amounts of formaldehyde gas. The products achieve Class E1, Release of formaldehyde specification to BS EN 300: 2006. Therefore, when the product is used in accordance with this Certificate, the quantity of formaldehyde gas emitted from the product alone will not raise the overall building level to an extent which will affect habitability.

10 Maintenance

As the product has suitable durability (see section 11) will normally be confined within the building structure and, in most cases, will be covered with finishes, maintenance is not required.

11 Durability



- 11.1 The product has adequate durability and will have a service life equal to that of the structure in which it is incorporated.
- 11.2 Care should be taken when designing, detailing and constructing buildings to ensure that moisture does not accumulate within the product.
- 11.3 Under normal conditions of use the product is unlikely to suffer damage, but if damage does occur, repairs can be carried out in accordance with the Certificate holder's instructions.

12 Reuse and recyclability

As wood-based materials, the product can be recycled.

Installation

13 General

- 13.1 The product is easily cut and fixed using conventional woodworking tools. Normal precautions should be taken to avoid inhalation of wood dust when cutting, drilling and sanding the products.
- 13.2 The product can withstand normal site handling and fixing. Damaged panels should not be used. Normal safety precautions should be observed when handling large products.

14 Procedure

Installation of the product should be in accordance with PD CEN/TR 12872 : 2014 or BS 8103-3 : 2009 and the manufacturer's recommendations.

Technical Investigations

15 Tests

Tests were carried out to determine:

- the product's material characteristics in accordance with the requirements of BS EN 300: 2006 for OSB/3
- reaction to fire classification in accordance with BS EN 13986 : 2004.

16 Investigations

16.1 The manufacturing process was evaluated, including the methods adopted for quality control, and details were obtained of the quality and composition of the materials used.

16.2 An assessment was made of the product's durability and behaviour in relation to moisture.

16.3 Calculations were carried out in accordance with BS EN 1995-1-1: 2004 to determine the racking resistance of the product.

Bibliography

BS 5250: 2021 Code of practice for control of condensation in buildings.

BS 8103-3: 2009 Structural design of low-rise buildings — Code of practice for timber floors and roofs for housing

BS EN 300: 2006 Oriented Strand Products (OSB) — Definitions, classification and specifications

BS EN 335 : 2013 Durability of wood and wood-based products — Use classes: definitions, application to solid wood and wood-based products

BS EN 594 : 2011 Timber structures — Test methods — Racking strength and stiffness of timber frame wall panels

BS EN 1995-1-1 : 2004 + A2 : 2014 Eurocode 5 : Design of timber structures — General — Common rules and rules for buildings.

BS EN 12524: 2000 Building materials and products — Hygrothermal properties — Tabulated design values

BS EN 13986 : 2004 + A1 : 2015 Wood-based panels for use in construction — Characteristics, evaluation of conformity and marking

BS EN ISO 10456 : 2007 Building materials and products — Hygrothermal properties — Tabulated design values and procedures for determining declared and design thermal values

BS EN ISO 12572 : 2016 Hygrothermal performance of building materials and products — Determination of water vapour transmission properties

PD CEN/TR 12872: 2014 Wood-based panels — Guidance on the use of load-bearing products in floors, walls and roofs

BS EN ISO 9001 : 2015 Quality management systems — Requirements

Conditions of Certification

16 Conditions

16.1 This Certificate:

- · relates only to the product/system that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

16.2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

16.3 This Certificate will remain valid for an unlimited period provided that the product/system and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- · continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

16.4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

16.5 In issuing this Certificate the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- actual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to CE marking.

16.6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.